

1. 52" x 57" clear inside hoistway dimensions when using an accordion style solid gate.
2. 8" [10" for EON Doors] minimum pit built to withstand a 3,900 lb. load.
3. 96" clear hoistway overhead (106" for EON Doors) for Std. cab. 100" for 7'-4" cabs and 108" (120" for EON Doors) for 8'-0" cabs.
4. 12" minimum return on rail side wall [Refer to your Territory Sales Manager for EON Door Returns]. If this cannot be obtained, contact office for approval.
5. If masonry construction, rail wall needs to be poured
6. Rail side blocking for wood frame hoistways must be two 2 x 12's sandwiched together, running vertically the entire length of the hoistway 12" on center of either side of the rail wall centerline. (Please see rail wall structural drawing.)
7. Any travel distances over 28'-0" will incur a special order charge for larger piston travel. (Add approximately one month to the standard delivery time.)
8. Machine room to be located adjacent to rail wall on first floor.
9. Remote machine rooms to be approved by office.
10. Machine room to be 48" x 48" or large enough to accommodate pump and controller without restricting access, and as per code.
11. Hoistway anchorage support.