

1. 52" x 57" clear inside hoistway dimensions when using an accordion style solid gate.
2. 8" [10" for EON Doors] minimum pit built to withstand a 5,100 lb. load.
3. 96" clear hoistway overhead (106" [113" Above Door Access] for EON Doors) for Std. cab. 102" for 7'4" cabs and 110" (120" [127" Above Door Access] for EON Doors) for 8'-0" cabs
4. 12" minimum return on rail side wall [Refer to your Territory Sales Manager for EON Door Returns]. If this cannot be obtained, contact office for approval.
5. If masonry construction, rail wall needs to be poured solid.
6. Rail side blocking for wood frame hoistways must be two 2 x 12's sandwiched together, running vertically the entire height of the hoistway 12" on center of either side of the rail wall centerline (28".) (Please see rail wall structural drawing).
7. Legal machinery space with access doors. (Please see access door drawing).
8. Hoistway anchorage support.